

BUILDING SAFETY CERTIFICATE**APPENDIX X1**

Ref : Stability Certificate Dt 01.02.2024

Date : 28.06.2024

Certified that the existing Building **ABS GLOBAL SMART SCHOOL** (Name of the Building or Premises)at 60 Feet Scheme Road, off J.N.Road, Periyakuppam Village, Thiruvallur, 602 001 (Address) Comprised of Ground Floor Area : 1721.42 Sqm and First Floor of 1721.42 Sqm occupied by ABS Global Smart School (Name of the Institution) Run by ABS Global School Trust have Complied with the Building Safety requirements in accordance with National Building code rules and verified by the concerned Engineer on 25.06.2024 in the Presence of Dr.S.Sakthi Balasundaram, Secretary of ABS Global Smart School, No.16,J.N.Road,V.M.Nagar, Thiruvallur (Name and Address of the Manager/ Secretary or his representative) and that the building / Premises is fit for occupancy up to classes XII with effect from 01.04.2023 to 31.03.2026 for a **Period of Three Years** in accordance with rules and subject to compliance of the specific conditions as appended.

Specific conditions as appended.

1. Structural Alteration / Deviation Should Not be Carried out to a part / whole Building without Prior Permission from the Competent Authority. If any additional construction is made subsequently structural soundness certificate has to be obtained.
2. Any Construction / Repairs/ Alteration work should not be carried out during School working hours. All Necessary safety standards and Norms has to be Strictly adhered / Followed.
3. All Electrical Cables should not be loosely Run on the open ground/ flooring it has to be put in pvc conduits. All panel boards has to be kept in lock and key position with utmost safety and precaution. Lift work has to completed and periodic license has to renewed.
4. AC Sheet / Metal sheet roof shed, Compound wall, welcome arch, all Semi/ Non – Permanent Structure is not Considered in this Certificate. If any deviation / violations/ Lapse in safety norms are found at a later period after issue of this Report / License The Engineer is not held responsible.

Issued on 28.06.2024 at Chennai by

Strike out whichever is not applicable.

Signature with Seal :

J.VARA PRASAD,
PGDCM.,C.Eng.FIV.,MIE.,MICA.,M.I.Struct E.,
Chartered Engineer,
Approved Engineer in Collector's Panel,
Competent Person to Issue Stability Certificate
No. 283/35, 2nd Floor, Jai Hind Flats,
Belly Area, NR, Chinnaya School,
Anna Nagar West, Chennai - 600 040.
Cell : 99629 87103, 94433 79627
Off : 76593 94343, Ph : 644 - 2626 0799